

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF EAST LOGAN WATER)	
DISTRICT FOR A DEVIATION FROM THE)	
REQUIREMENTS OF 807 KAR 5:066, SECTION)	CASE NO. 89-269
5(4) REGARDING WATER STORAGE)	

O R D E R

By application received September 26, 1989, East Logan Water District ("East Logan") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. East Logan states in its application that its average daily water usage, including unaccounted-for water, is approximately 200,000 gallons, and its current water storage capacity is 200,000 gallons.

The Commission, having reviewed the application and being advised, finds that:


1. East Logan is in substantial compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4), and therefore its application for a deviation is moot.


2. East Logan has obtained financing to construct an additional new storage tank which will be completed by the spring of 1990.


IT IS THEREFORE ORDERED that the application of East Logan for permission to deviate from the requirements of Commission 807 KAR 5:066, Section 5(4), is dismissed.

Done at Frankfort, Kentucky, this 17th day of October, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director